

Tender Reference No. : 2025-26/001-NLF-TMDHC

Tender for the Provision of Cleansing, Building Repair and Maintenance Services for ELCHK, Tuen Mun District Health Centre

Tender Query No.1

For 1.2 Building Repair and Maintenance Services, is there any designated brand and model for the sensor water tap? If so, please provide details.

Answer: No designated brand or model.

Tender Query No.2

For 1.2 Building Repair and Maintenance Services, could you specify the size of ball float valve required for the water tank in your quotation?

Answer: One-inch ball float valve.

Tender Query No.3

For 1.2 Building Repair and Maintenance Services, how many water tanks should require cleansing services, and what is the capacity of each?

Answer: One 1000L fresh water tank in Core Centre.

Tender Query No.4

For 1.1 Cleaning Services, please indicate which centers should require cleaning services and to be provided the consumables (e.g. toilet paper, M-fold towel, soap, garbage bag, etc.) for the toilet.

Answer: According to the Manpower Requirements in PART III – SPECIFICATIONS, only one staff toilet is available inside Melody Garden Satellite Centre. The successful Tenderer needs to provide cleaning equipment and related cleaning consumables, but not items for staff use (e.g., tissue, M-Fold Towel, hand soap and garbage bags, etc.)